

Financial Analysis of Solar Power for Greensburg, Kansas

A project supported by the NSF SC&C Program - Award No. 2125548



Anil Pahwa, Reza Nematirad, Shweta Dahale, Bala Natarajan, Hongyu Wu
Kansas State University

Acknowledgments

- National Science Foundation for financial support for the project.
- City of Greenburg and Kansas Power Pool (KPP) for supporting the research and providing load and cost data.
- Kansas State University Agricultural Extension for the weather data.
- Colleagues and graduate students. Specially, Reza Nematirad for all the calculations included in this presentation.

Outline

- Some information on Greensburg
- Data used for analysis
- Examples of load and PV generation
- Results of PV alone
- Battery selection methodology
- Results

The seal of Kansas State University is partially visible on the left side of the slide. It features a circular design with the text "KANSAS STATE UNIVERSITY" and "FEBRUARY 1863" around the perimeter. In the center, there is a figure holding a sheaf of wheat and a plow, with the motto "WISDOM BY DEEDS" above it.

City of Greensburg

- Located in south-central Kansas.
- Hit by a massive EF 5 tornado on May 4, 2007.
- Since then the community has rebuilt as a model community for sustainable living while putting “green” in Greensburg.
- One observer described Greensburg as “a unique place where rural values meet global vision.”
- Greensburg’s electricity is 100% wind power.
- The restored community has a population of approximately 850 people.


Data Used

- Hourly load for 2019 to 2021
- Hourly solar irradiation for 2019 to 2021
- Technical and Financial

| | | |
|------------------------------|----------------------------------|------------------------------|
| PV module (\$ / W) | Inverter (\$ / W) | Equipment (\$ / W) |
| 0.035 | 0.04 | 0.18 |
| Overhead (\$ / W) | O&M (\$ / kW) | Transformer (\$) |
| 0.1 | 15 | 150,000 |
| Energy cost \$ / kWh | Power cost (\$ / kW) | Tax credit (%) |
| 0.025 | 22 | 30 |
| Initial battery (\$ / kWh) | Replacement battery (\$ / kWh) | Project lifetime |
| 150 | 100 | 20 years |
| Labor (\$ / W) | Discount rate | Battery roundtrip efficiency |
| 0.1 | 0.08 | 0.9025 |
| Inverter coefficient | Battery efficiency | Battery utilization |
| 1.2 | 0.95 | 0.7 |


Example of Load and PV

01/23/2019 peak demand day for PV size of 1 MW






07/31/2019 peak demand day for PV size of 1 MW






| Case | Energy cost (Cent/kWh) | Peak demand charge (\$/kW) | Tax rebate (%) |
|--------|------------------------|----------------------------|----------------|
| Case 1 | 2.654 | 10.64 | 30 |
| Case 2 | 2.5 | 22 | 30 |
| Case 3 | 3.75 | 16.5 | 30 |
| Case 4 | 5 | 11 | 30 |

Benefit (PW) = Energy Bill Reduction + Demand Bill Reduction – Net Cost



Battery Operation with Grid




Battery fully charged and discharged in 24 hours

Smaller Battery

Discharging Area = Charging Area * Battery Roundtrip Efficiency


Battery Size = Charging Area * Charging Efficiency / Battery Utilization Factor

Peak Load Distribution



PV Size = 2000 kW
Battery = 4000 kWh

Peak Load Threshold




PV Size = 2000 kW

Optimal PV/Battery Sizes

| PV size (kW) | 400 | 800 | 1200 | 1600 | 2000 | 2400 | 2800 | 3200 | 3600 |
|--------------------|------|------|------|------|------|------|------|------|------|
| Battery size (kWh) | 6200 | 5000 | 3200 | 4400 | 4600 | 5400 | 4600 | 4200 | 4400 |
| Threshold (kW) | 2167 | 2090 | 2078 | 1995 | 1971 | 1952 | 1958 | 1955 | 1931 |

Present Worth of Benefit



Best Option

PV Size = 1200 kW

Battery = 3200 kWh

Benefit = Energy Bill Reduction + Demand Bill Reduction – Net Cost


Results (Present Worth)

| | Without PV-battery | With PV | With PV-battery |
|---------------------|--------------------|-----------|-----------------|
| Energy cost (\$) | 3,788,907 | 3,337,719 | 3,365,366 |
| Peak cost (\$) | 6,913,926 | 6,539,467 | 5,166,301 |
| Equipment cost (\$) | 0 | 1,016,013 | 1,350,792 |
| Benefit (\$) | - | -190,366 | 820,373 |

PV Size = 1200 kW
Battery = 3200 kWh
Benefit of \$83539/yr
Payback Period of 6 years



20-Year Monte Carlo Analysis



Conclusions

- If the peak load does not coincide with peak PV hours, PV alone does not help in reducing demand charges.
- PV combined with battery gives positive results.
- The proposed statistical method is valuable for determining the best battery and PV size combination for planning new installations. It works only with real data.

